



Product Service

CERTIFICATE

No. Z2 125347 0001 Rev. 00

Holder of Certificate: **Solar Panel Ltd.**

Preslav 2
7700 Targovishte
BULGARIA

Certification Mark:



Product:

Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
Mono-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062353401-00

Valid until: 2029-03-20

Date, 2024-03-21

(Zhulin Zhang)

CERTIFICATE

No. Z2 125347 0001 Rev. 00

Model(s):

SP-BG-144-xxx, xxx = 540 to 560 in steps of 5
SP-BG-132-xxx, xxx = 495 to 510 in steps of 5
SP-BG-120-xxx, xxx = 450 to 465 in steps of 5
SP-BG-108-xxx, xxx = 405 to 420 in steps of 5
xxx is standing for rated output power at STC

Parameters:

Construction:	Framed with Junction box, Cable and Connectors.
Test Laboratory:	Changzhou HuaYang Inspection and Testing Technology Co., Ltd. No.8 Lanxiang Road, Wujin Economic Development Zone Changzhou, Jiangsu, China
Safety Class:	Class II
Maximum System Voltage:	1500V DC
Fire Safety Class:	Class C according to UL790

Tested according to:

IEC 61215-1:2021
EN IEC 61215-1:2021/AC:2021
IEC 61215-1-1:2021
EN IEC 61215-1-1:2021
IEC 61215-2:2021
EN IEC 61215-2:2021
IEC 61730-1:2016
EN IEC 61730-1:2018/AC:2018
IEC 61730-2:2016
EN IEC 61730-2:2018/AC:2018